



LINE SURGE DAMAGES INSURED EQUIPMENT



LOSS DETAILS

Nature of Business: *Circuit Board
Manufacturer*

Type of Equipment: *Various*

Final Loss

Settlement Amount: *\$78,463.79*

At about 2:00 pm the Insured lost most of their power due to a single-phase loss from Hydro, putting the entire facility into partial darkness. About 15 minutes later, there was a total power loss that resulted in sending 150 employees out into the street. Upon the restoration of power 1½ hours later, a line surge ensued, which resulted in extensive motor burnouts, damage to various pieces of equipment, contamination of several plating tanks, loss of production and data processing corruption.

Insured incurred a loss of \$55,121.00 in Business Interruption and \$23,342.79 in Property Damage.

*The Boiler Inspection and Insurance Company of Canada
Brings Engineering and Inspection to Insurance*