



CULTURAL CENTRE'S BOILER CRACKED



LOSS DETAILS

Nature of Business: Community Centre

Type of Equipment: Cast Iron Heating Boiler

Age of Equipment: 3 years old

Final Loss

Settlement Amount:

Physical Damage \$14,293.48

On New Year's day between 5:30 a.m. and 10:30 a.m. a short circuit occurred in an electrical connection box. The failure produced a total shut down of the boiler's pump and low water cut off device. When the boiler "dry fired" it overheated, cracking all 7 lower end sections.

Attempts to weld the cracked sections proved futile. The boiler had to be replaced with a new model.